

START

9513338.1885

0040897



Mr. John Grantham
State of Washington
Department of Ecology
Nuclear & Mixed Waste Program
P. O. Box 47600
Olympia, WA 98504-7600

FLUOR DANIEL, INC.

Date: June 3, 1994

Reference: Hanford Waste Vitrification Plant
DOE Contract DE-AC06-86RL10838
Fluor Contract 8457

Transmittal No.: WDOE-931

Dear Mr. Grantham:


TRANSMITTALWe enclosed 1 copy of the items listed below. These are issued per US-DOE request.

Response due to Fluor: N/A
Responds to: DOE REQUEST

NUMBER	REV	DATE	TITLE
DCN - 0176	0	06/03/94	<p>DCN TITLE:</p> <p>REVISION OF OPERATING REQUIREMENTS AND DESIGN STANDARDS FOR THE FIREWATER HEATER PUMP.</p> <p>NOTE: "FOR RCRA PART B PERMIT"</p>

Distribution:

R. L. Long - DOE-RL, w/0
TWP/AME Corresp Cntrl Cntr MSIN A5-10
(A160 PACKAGE), w/0
P. Felise - WHC-RL (MSIN G6-06), w/0
Environmental Data Management Center
(MSIN H6-08), w/1
D. Duncan - US EPA, Region X, w/0
M.D. Talbot, WHC -w/0



Very truly yours,

Nazy Eshraghi

R. S. Poulter
Project Director

RSP:DGL:nre

DESIGN CHANGE NOTICE

DCN - 0176

REV 0

PAGE 1 OF 9

DCN TITLE
Revision of operating
requirements and design
standards for the Firewater
Heater Pump.

DATE INITIATED

7 March 1994

PACKAGE NO.
A160

SECTION 1: DESCRIPTION OF CHANGE

This DCN revises the operating requirements for the Fire Water Heater Pump, PX-500-003, to conform to revised process requirements. Also, it revises the design standard for pumps from API-610 to ASME B73.1M.

FOR LIST OF AFFECTED DOCUMENTS, SEE SECTIONS 6 AND 7.

CAUSE OF
CHANGE:

- ☐ Field Change Request
☐ Supplier Disposition
☐ Deficiency Report
☐ Design Development
☐ Change Request
☐ TBD/Hold
☒ Other Title III
Review

N/A

Initiating Document(s)

SECTION 2: EVALUATION

WAPA DWG/SPEC? ☒ NO ☐ YES
QUALITY LEVEL 1 DWG/SPEC? ☒ NO ☐ YES
SAFETY CLASS 1 OR 2 DWG/SPEC? ☒ NO ☐ YES
SYSTEMS ANALYSES AFFECTED? ☒ NO ☐ YES
MULTI-DISCIPLINE CHANGE? ☒ NO ☐ YES

IF "YES", ADDITIONAL
REVIEW REQUIRED BY:

REVIEWER COMMENTS
AND SIGNATURE/DATE

DCN Evaluated by: Systems Patricia Dumas ADM J. Chow Others _____

SECTION 3: APPROVED FOR CONSTRUCTION

Donald H. LaBounty
Originator

11 MAR 94
Date

Donald H. LaBounty for P. Berdell 11 MAR 94
Project/Resident Engineer Date

SECTION 4: CONCURRENCE

Patricia Dumas 4/23/94
Project Management Date

James E. Savage 4/25/94
Systems Date

Ching Yee 4/28/94
Independent Safety Date

Patricia Dumas 4-28-94
Quality Assurance Date

Frank Stokes 4-26-94
Configuration Management Date

SECTION 5: RELEASED FOR CONSTRUCTION

PE STAMP REQUIRED? ☐ NO ☒ YES

Patricia Dumas 4/25/94
WHC Date

R. Walburn 5-25-94
UCAT Date

James E. Savage 5/25/94
DOE Date

COMMENTS:



FLUOR DANIEL

9513358.1857

US DEPARTMENT OF ENERGY
HANFORD WASTE VITRIFICATION PLANT**DESIGN CHANGE NOTICE**

REV

DISCIPLINE

PKG. NO.

PAGE

DCN - 0176

0

Mech

A160

2

PREPARED BY: D. G. LaBounty

Date: 7 March 1994

DISCIPLINE ENGINEER: D. G. LaBounty

Date: 7 March 1994

SECTION 6: CONSTRUCTION DOCUMENTS AFFECTED

DOCUMENT NUMBER	SHT/ PAGE	REV NO	DOCUMENT NAME	INCLD Y/N	DESCRIPTION OF CHANGE
B-595-C-A160- 15541	1, 6, 7, 8, 9, 10, A160- DS-1	1	Fire Water Unit Heater Pump	Yes	Revised operating conditions and governing pump design standard.

SECTION 7: NON-CONSTRUCTION DOCUMENTS AFFECTED

This section references affected items such as P&IDs or calculations/analyses, but they are generally not included in DCN package.

DOCUMENT NUMBER	SHT/ PAGE	REV NO	DOCUMENT NAME	DESCRIPTION OF CHANGE
H-2-123358	2	9	P&ID SYSTEM 50 FIRE AND PROCESS WATER STORAGE	Revised Differential Pressure of PX-500-003 Fire Water Heater Pump



FLUOR DANIEL

U. S. Department of Energy
Hanford Waste Vitrification Plant
Richland, Washington
DOE Contract DE-AC06-86RL10838
CENTRIFUGAL PUMPS

NO.	BY	REVISION	SHEET NO.	REV.
DATE			A160-DS-1	1
			DATE	CONTRACT
			07-23-91	045734
			TAG NO.	PX-500-003
			TECHNICAL SECT NO.	15541
			FOR CLIENT USE	
			DESIG	CHK'D
			JJ	CD
			APPR'D	

ISSUED FOR DEPARTMENT OF ECOLOGY PERMIT ONLY

ALL ITEMS SHALL COMPLY WITH GENERAL SPECIFICATION SHEETS:

A160-15541

Service: <u>FIRE WATER UNIT</u>	No. Motor Driven: <u>1</u>	No. Pumps Req.: <u>1</u>
<u>HEATER PUMP</u>	Pump Tag No.: <u>PX-500-003</u>	No. Turbine Driven: _____
Pump Mfr.: _____	<u>FIRE WATER UNIT HEATER PUMP</u>	Pump Tag No.: _____
Size & Type: _____	Motor Tag No.: <u>SAME</u>	Turbine Tag No.: _____
No. Stages: _____	Motor Provided By: <u>PUMP MFR.</u>	Turbine Provided By: _____
Serial No.: _____		Turbine Mounted By: _____

LIQUID	OPERATING CONDITIONS	SITE CONDITIONS
Name: <u>WATER</u>	Capacity (U.S. GPM): Normal <u>27</u> Rated <u>30</u>	Temp. (°F): Max. <u>110</u> Min. <u>60</u>
Operating Temperature (°F): Normal <u>60</u> Max. <u>80</u> Min. <u>45</u>	Discharge Pressure (PSIG): <u>21</u>	Rel. Humid. (%): Max. <u>300</u> Min. <u>30</u>
Specific Gravity: @ <u>60</u> °F = <u>1.00</u>	Suction Pressure (PSIG): Max. _____ Rated <u>-1.8</u>	Altitude (Feet): _____
Vapor Press. (PSIA): <u>0.256</u>	Differential Pressure (PSI): <u>23</u>	<input checked="" type="radio"/> Indoor <input checked="" type="radio"/> Heated <input type="radio"/> Roof
Viscosity (CP): @ <u>60</u> °F = <u>1.129</u>	Differential Head (Feet): <u>53.1</u>	<input type="radio"/> Outdoor <input type="radio"/> Unheated <input type="radio"/> Sun
Corrosion/Erosion Caused By: <u>NONE</u>	NPSH Available (Feet): <u>28.2</u>	Area Classification: <u>3</u>
Remarks: <u>CONTINUOUS OPERATION</u>	Hydraulic Power (HP): <u>0.13</u>	Other: _____
		Remarks: <u>DCN-0176</u>

PERFORMANCE (To Be Completed By Manufacturer)

Proposal Curve No.: _____	Minimum Continuous Flow (GPM): _____	NPSH Required (Feet Water): _____
Speed (RPM): _____	Thermal _____ Stable _____	3% Head Drop _____
Efficiency (%): _____	Max. Head Rated Imp. (Feet): _____	Suction Specified Speed: _____
Rated Power (BHP): _____	Max. Power Rated Imp. (BHP): _____	

CONSTRUCTION (To Be Completed By Purchaser and Manufacturer)

NOZZLES	SIZE	RATING	FACING	LOCATION
Suction	<u>1 1/2</u>	<u>150</u>	<u>R. F.</u>	
Discharge	<u>1</u>	<u>150</u>	<u>R. F.</u>	

Casing Mount: <input checked="" type="checkbox"/> Foot <input type="checkbox"/> Bracket	Impeller Diameter (Inches): Rated _____ Max. _____ Min. _____
Centerline <input type="checkbox"/> Near Cntrl. <input type="checkbox"/> Inline	Rated _____ Max. _____ Min. _____
Casing Split: <input type="checkbox"/> Axial <input checked="" type="checkbox"/> Radial	Impeller Type: <input checked="" type="checkbox"/> Open <input type="checkbox"/> Closed
Casing Type: <input type="checkbox"/> Diffuser <input type="checkbox"/> Staggered	Imp. Suction: <input checked="" type="checkbox"/> Single <input type="checkbox"/> Double
<input checked="" type="checkbox"/> Single Volute <input type="checkbox"/> Double Volute	Imp. Mount: <input type="checkbox"/> Btwn. Brgs <input checked="" type="checkbox"/> Overhung
Max. Allowable Pressure (PSIG): At 60 °F _____	Rotation (Coupling End): <input type="checkbox"/> CW <input type="checkbox"/> CCW
At Norm. Pump Temp. _____	Bearing (Type/Number): _____
Hydro Test Pressure (PSIG): _____	Radial _____
Lubrication Type: <input type="checkbox"/> API 614	Thrust _____
<input checked="" type="checkbox"/> Grease <input type="checkbox"/> Ring Oil <input type="checkbox"/> Oil Mist	Coupling: _____
<input type="checkbox"/> Flood <input type="checkbox"/> Finger <input type="checkbox"/> Pressure	Manufacturer _____
Remarks: _____	Type/Model _____

MISC. CONNECTIONS	Drain	_____
Vent	_____	
Pressure Gauge	_____	
Warm Up	_____	
Balance	_____	

Manufacturer	_____
Type/EXPIRES	<u>9-11-94</u>
Size/No. Rings	_____
Mechanical Seal:	_____
API Class Code	<u>X</u>
Manufacturer	_____
Model	_____
Mfr. Code	_____
<input type="radio"/> Cartridge Type Required	
Gland Type/Mat'l.: _____	
Gland Flange Tape Required for:	
<input type="radio"/> Quench <input checked="" type="radio"/> Flush <input type="radio"/> Drain <input type="radio"/> Vent	

951333B.1889


Delete:

"AMERICAN PETROLEUM INSTITUTE (API)
API Std 610 1989 Centrifugal Pumps for General Refinery
Service, 7th edition"


Add new publication:

"AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME):
ASME B73.1M 1991 Specifications for Horizontal End Suction
Centrifugal Pumps for Chemical Process"

**ISSUED FOR DEPARTMENT
OF ECOLOGY PERMIT ONLY**



EXPIRES 9-11-94

 FLUOR DANIEL		U.S. DEPARTMENT OF ENERGY HANFORD WASTE VITRIFICATION PLANT		DESIGN CHANGE NOTICE		
DESCRIPTION OF CHANGE Revision of design conditions and standards for the Firewater Heater Pump				BASE DOC. NO. B-595-C- A160-15541 SHT/PG. 1 REV. 1		
				DISCIPLINE: Mech		
PREPARED BY: D. G. LaBounty		DATE: 7Mar94		DCN - 0176	REV 0	PAGE 4
DISCIPLINE ENGINEER: D. G. LaBounty		DATE: 7Mar94				

2.2.1 General Requirements

Delete the sentence in the first paragraph:


"The pump operating point shall be within 10 percent and to the left of the peak efficiency on the pump performance curve.

In the second paragraph, revise the phrase "and API STD 610" to read "and ASME B73.1M."

**ISSUED FOR DEPARTMENT
OF ECOLOGY PERMIT ONLY**



EXPIRES 9-11-94


 FLUOR DANIEL		U.S. DEPARTMENT OF ENERGY HANFORD WASTE VITRIFICATION PLANT		DESIGN CHANGE NOTICE		
DESCRIPTION OF CHANGE Revision of design conditions and standards for the Firewater Heater Pump				BASE DOC. NO. B-595-C-A160-15541 SHT/PG. 6 REV. 1		
				DISCIPLINE: Mech		
PREPARED BY: D. G. LaBounty		DATE: 7Mar94		DCN - 0176	REV 0	PAGE 5
DISCIPLINE ENGINEER: D. G. LaBounty		DATE: 7Mar94				

951333B.1891


2.2.6 Coupling

Revise the phrase: "at 1750 rpm" to read "at full load rpm."

**ISSUED FOR DEPARTMENT
OF ECOLOGY PERMIT ONLY**



EXPIRES 9-11-94


 FLUOR DANIEL		U.S. DEPARTMENT OF ENERGY HANFORD WASTE VITRIFICATION PLANT		DESIGN CHANGE NOTICE	
DESCRIPTION OF CHANGE Revision of design conditions and standards for the Firewater Heater Pump				BASE DOC. NO. B-595-C- A160-15541 SHT/PG. 7 REV. 1	
				DISCIPLINE: Mech	
PREPARED BY: D. G. LaBounty		DATE: 7Mar94		DCN - 0176	REV 0
DISCIPLINE ENGINEER: D. G. LaBounty		DATE: 7Mar94			

9513338.1892


2.2.9 Motor

Delete the phrase: "1800 RPM,"

**ISSUED FOR DEPARTMENT
OF ECOLOGY PERMIT ONLY**



EXPIRES 9-11-94


 FLUOR DANIEL		U.S. DEPARTMENT OF ENERGY HANFORD WASTE VITRIFICATION PLANT		DESIGN CHANGE NOTICE		
DESCRIPTION OF CHANGE Revision of design conditions and standards for the Firewater Heater Pump				BASE DOC. NO. B-595-C- A160-15541 SHT/PG. 8 REV. 1		
				DISCIPLINE: Mech		
PREPARED BY: D. G. LaBounty		DATE: 7Mar94		DCN - 0176	REV 0	PAGE 7
DISCIPLINE ENGINEER: D. G. LaBounty		DATE: 7Mar94				


9513338-1893

2.2.12 Factory Acceptance Tests (FATs)

In paragraph "B" revise "API STD 610" to read "ASME B73.1M."

**ISSUED FOR DEPARTMENT
OF ECOLOGY PERMIT ONLY**




 FLUOR DANIEL		U.S. DEPARTMENT OF ENERGY HANFORD WASTE VITRIFICATION PLANT		DESIGN CHANGE NOTICE	
DESCRIPTION OF CHANGE Revision of design conditions and standards for the Firewater Heater Pump				BASE DOC. NO. B-595-C- A160-15541 SHT/PG. 9 REV. 1	
				DISCIPLINE: Mech	
				PREPARED BY: D. G. LaBounty DATE: 7Mar94	
DISCIPLINE ENGINEER: D. G. LaBounty DATE: 7Mar94				DCN - 0176 REV 0 PAGE 8	

9515338.1894


2.5 Inspection and Testing

Revise the phrase: "...API STD 610, Paragraph 4.1, 4.2, 4.3"
to read "ASME B73.1M, Paragraph 5.2."

**ISSUED FOR DEPARTMENT
OF ECOLOGY PERMIT ONLY**



EXPIRES 9-11-94

 FLUOR DANIEL		U.S. DEPARTMENT OF ENERGY HANFORD WASTE VITRIFICATION PLANT		DESIGN CHANGE NOTICE		
DESCRIPTION OF CHANGE Revision of design conditions and standards for the Firewater Heater Pump				BASE DOC. NO. B-595-C- A160-15541 SHT/PG. 10		
				REV. 1		
				DISCIPLINE: Mech		
PREPARED BY: D. G. LaBounty		DATE: 7Mar94		DCN - 0176	REV 0	PAGE 9
DISCIPLINE ENGINEER: D. G. LaBounty		DATE: 7Mar94				